

**Addendum No. 1  
to the Bidding Documents**

**Recreation Park Improvements Phase 2– East  
Town of Red Hook**

**Issued – January 29, 2020**

Under the provisions of Article 7 of Section 00200, Instructions to Bidders, Bidders are informed that the Bidding Documents for the above-mentioned Project are modified, corrected, and/or supplemented as follows. Addendum No. 1 becomes part of the Bidding Documents.

Acknowledge receipt of this addendum by inserting its number on Page 00410-2, Article 4.2 of the Bid form. Failure to acknowledge receipt of the Addendum may subject the Bidder to disqualification.

**Drawing Changes**

**Item 1-1 Drawing C-201, Sheet 4 of 10 – Proposed Conditions**

**Add** the following to Drawing C-201:

Detectible warning strips shall be provided at the end of both walkways. Please refer to Exhibit #1.

**Bidding Period Questions & Responses**

The following responses/clarifications are based on questions raised during bidding period.

For the Paving areas between the parking bollards and the chain link fence, which paving detail should apply?

*Contractors should refer to detail on 1 on Sheet C-301 (HMA Pavement Detail) for all pavement between the bollards and chain link fence. The HMA walkway shall only be provided on the park side of the chain link fence. Exhibit #1 has been attached for clarification.*

Are there any detectable strips needed at transition from park walkways / sidewalks to the parking lot?

*Detectible warning strips will be required. Exhibit #1 has been attached and show detectible warning strips provided in two locations. The exhibit should be amended to the bidding documents.*

Why was the chain-link fence split out as an alternate?

*The chain link fence was split out for funding purposes. Alternate #3, including fence, gates and appurtenances will be awarded with the base bid.*

Is the electrical work to be completed by the Town's electrician or the Contractor?

*All electrical work shall be performed by a licensed electrician hired or employed by the awarded Contractor.*

Does Alternate #2 include both bathrooms?

*Alternate #2, which includes the replacement of tile floor includes both the men's and women's bathroom.*

Sheet 201 – Proposed Condition states that the HMA Pavement within the playground shall be provided per Playground Plan. Can you provide clarification?


*The pavement area within the existing playground area including the four-square courts, is being provided for bidding purposes. The contractor will be required to layout the area with the engineer to confirm the locations of the pathway within the playground. Field changes may be required but the area of pavement will remain the same. For the purposes of bidding contractors should carry 1600 SF of HMA walkway pavement for this area.*

Can a pre-bid meeting attendance form be provided?

*The pre-bid meeting attendance form is attached for your review.*


END OF ADDENDUM NO. 1

J:\R\R5004 Town of Red Hook\005 - Rec Park West\Bidding\Rec Park East - Phase 2\Addenda\Addendum #1\Addendum #1 - January 29, 2020.doc




**NOTES**

1. THIS PLAN IS BEING PROVIDED FOR CLARIFICATION OF ADDENDUM #1.
2. CLOUDED ITEMS REPRESENT A CHANGE TO BIDDING DOCUMENTS.



**PEDESTRIAN SECTION**



**DOME SPACING PLAN**

**NOTES**

1. CARE SHALL BE TAKEN TO ASSURE A UNIFORM GRADE ON THE WALKING SURFACE, FREE OF SNAGS AND SHORT GRADE CHANGES.
2. TACTILE WARNING STRIP SHALL MEET ALL ACCESSIBILITY CODES.
3. USE 24"x24" PAVER TILE BY WAUSAU TILE, WAUSAU WISCONSIN, OR APPROVED EQUAL.

**DETECTABLE WARNING SURFACE**

**DETAIL**

NO SCALE

6
C-103

**ISSUE FOR BIDDING**

**Recreation Park Improvements Phase 2 - East**

Town of Red Hook

Red Hook, NY

MARK	DATE	DESCRIPTION

PROJECT NO:	R5004-005
DATE:	01/28/2020
FILE:	R5004-005-ADDENDUM #1.dwg
DRAWN BY:	RMM
CHECKED:	BKN
APPROVED:	

ADDENDUM #1  
 EXHIBIT #1  
 SCALE: AS SHOWN

## Town of Red Hook Recreation Improvement Phase 2 – East

### Optional Pre-Bid Conference

**Location: Linden Ave., Red Hook Ny**

**Date: January 22, 2020 at 8:00 A.M.**

Company	G.C.? (yes or no)	Address	Phone & Fax	Email
Turco Golf Inc.	Yes	430 Montclair Ave, Pompton Lakes, NJ 07442	P: 845-357-9300 F: 845-357-8086	dennis@grasskeepers.net
Del Signore Companies	Yes	42 Brick Church Road Troy, NY 12180	P: 518-279-1642 F: 518-279-1792	tsantoro@delsignorecompanies.com
Maeda Construction	Yes	PO Box 49 Stratsburg, NY 12580	P: 845-706-7755 F:	bert@maedaconstruction.com
Pro-Services	No	54 Elizabeth Street Red Hook, NY 12571	P: 845-464-5980 F:	mike@pro0servicesinc.net
Meyer Contracting	Yes	12 Charles Street Pleasant Valley, NY 12569	P: 845-635-1416 F: 845-635-154	estimating@meyercontracting.com
VanEtten Contracting	Yes	PO Box 422 Cornwall, NY 12518	P: 845-534-2434 F:	jerry@vecontract.com

J:\R\R5004 Town of Red Hook\005 - Rec Park West\Bidding\Rec Park East - Phase 2\Addenda\Addendum #1\Prebid Attendance form.doc